

Approval Number: 1906513  
Test Report: J-00321729



Water Regulations Advisory Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

24<sup>th</sup> April 2019

Progum Elastomer Technology Co Ltd  
5F-9, No 258 Liancheng Road,  
Jhonghe District,  
New Taipei City,  
23553,  
Taiwan

**WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)  
CONSECUTIVE MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**RUBBERS - ETHYLENE PROPYLENE DIENE MONOMER (EPDM) - MATERIAL ONLY.**

**5365**

'EP7037K'. Black coloured, compression moulded EPDM material. Shore hardness 72. Tested in-radius size 1.0mm. For use with water up to 85°C.

**APPROVAL NUMBER: 1906513**

**APPROVAL HOLDER: PROGUM ELASTOMER TECHNOLOGY CO LTD**

This is a re-approval of 1405509 which is valid between May 2014 and May 2019.

The Scheme reserves the right to review approval.

Approval 1906513 is valid between June 2019 and June 2024

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival  
Approvals & Enquiries Manager  
Water Regulations Advisory Scheme