

Approval Number: 1705510
Test Report: MAT/LAB 132M



Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

26th April 2017

Progum Elastomer Technology Co Ltd
5F-9, No 258 Liancheng Road,
Jhonghe District,
New Taipei City,
23553,
Taiwan

**WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
CONSECUTIVE MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

RUBBERS - NITRILE (ACRYLONITRILE BUTADIENE) MATERIAL ONLY.

5395

NP7055K. Black coloured, compression moulded NBR rubber material. Tested in-radius size 1.00mm. Shore hardness 72. For use with water up to 85°C.

APPROVAL NUMBER: 1705510
APPROVAL HOLDER: PROGUM ELASTOMER TECHNOLOGY CO LTD

This is a re-approval of 1204551 which is valid between April 2012 and April 2017.

The Scheme reserves the right to review approval.
Approval 1705510 is valid between May 2017 and May 2022

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme